



**ATASCADERO FIRE DEPARTMENT
DRIVEWAY ACCESS CLEARANCE
FOR SHRUBS AND TREES**

NOTES:

1. THIS STANDARD IS REQUIRED ACCORDING TO THE WILDLAND URBAN INTERFACE CODE, CHAPTER 4, SECTION 403.2
2. DRIVEWAY MUST HAVE AN UNOBSTRUCTED WIDTH OF 12 FEET AND AN UNOBSTRUCTED HEIGHT OF 13 FEET SIX INCHES
3. THE UNOBSTRUCTED WIDTH IS THE TOTAL CLEAR ZONE WHETHER OR NOT THE 12 FOOT CLEAR ZONE IS ENTIRELY PAVED WITH ASPHALT OR BASE
4. TREES OVERHANGING THE DRIVEWAY MUST BE TRIMMED TO A MINIMUM HEIGHT OF 13 FEET, 6 INCHES OVER THE ENTIRE CLEAR ZONE



CITY OF ATASCADERO FIRE DEPARTMENT					
DESCRIPTION: DRIVEWAY CLEARANCE STANDARD					
APPROVAL:	DATE: 11/28/2012	REVISIONS	BY	APP	DATE
TOM PETERSON, FIRE MARSHAL					
DRAWN BY: DMA	DATE DRAWN: 11/28/12				

DRAWING NO. F-8
SCALE: N.T.S.